

	ALTERNATION HISTORY RECORDS变更记录					
Date 日期	Version 版本	Mark 标记	Page 页码	Description 描述	Drafter 制定者	Approver 审批者

Issued-date: 2024-06-24	Name	Specification Sheet –4532			
Revision	A		Page	1	
STANDARD MANUAL					




1. Features

The Gas Discharge Tube (GDT) is a protective device which is filled with certain proportion of noble gas, or mixed gas or other discharge media in the space between metal electrodes and metalized ceramics, and then sealed at high temperature to form a single gap or multi-gap switch type protective device. When the protected circuit or equipment suffers to surge, GDT will change from high impedance state to low impedance state and release the surge energy to reduce the residual voltage of the circuit, and then protect the equipment or human body from the hazard of transient over voltage.

Fast Response Stable Performance Over Surface Life High Current Rating Low Capacitance

High Insulation Resistance RoHS & REACH Compliant

2. Part Number System



2.1 LOGO Name:

Code	AL
LOGO	Aillen

2.2 <u>Size:</u>

Code	4532
Size	4.5*3.2

2.3 DC Breakdown Voltage:

Code	230	1200	3600
Voltage(VDC)	230 ±20%	1200±20%	3600±20%

2.4 Package

Code	TR
Package	Tape & Reel

Issued-date: 2024-06-24	Name	Specification Sheet –4532			
Revision	A		Page	2	
STANDARD MANUAL					



3. Product Information

3.1 Product Structure:

the vacuum component is filled with the fit Noble or mixed gas between the metal electrode and the metallized ceramic and welding them together by the high temperature and whether subjoin the wire and connection shape according to customer's requirement.

3.2 Main Material:

Electrode, Ceramic, Brazing material, Lead foot(SMD No Lead foot)

3.2Appearance:

Without dirt and crack, marking should be clear


3.3 Plating:

Electrode: ✓ Plating Tin; □ Plating nickel; Lead foot: ✓ Plating Tin;

3.4 Marking:

Blue

3.5 Reflow Profile





Issued-date: 2024-06-24	Name	Specification Sheet –4532			
Revision	A		Page	3	
STANDARD MANUAL					







Unit: mm






3. 7 Packing







Item	A0	В0	K0	P	W	Е
Dimensions/mm	3.7±0.1	4.9±0.1	3.5±0.1	8.0±0.1	12.0±0.3	1.75±0.1
Item	F	D0	Р0	P2	t	
Dimensions/mm	5.5±0.1	1.5+0.1/-0	4.0±0.1	2.0±0.1	0.4±0.05	

Issued-date: 2024-06-24	Name	Specification Sheet –4532			
Revision	A		Page	4	
STANDARD MANUAL					



4 Specifications (accordance with ITU-T Rec. K.12 and IEC 61643-311.)

	DC	Maximum		npulse
	Breakdown	Impulse Breakdown	Discharge Curren	
Model Name	Voltage	Voltage	8	/20µs
	(V)	(V)	((KA)
	100~2000V/S	$1000 \mathrm{V}/\mathrm{\mu s}$	1time	20time
4532-1200	1200±20%	1800	4	3

Madal Nama	Alternating Discharge Current	Impulse Life	Minimum Insulation Resistance	Maximum Capacitance
Model Name	(A)	(times)	$(G\Omega)$	(pf)
	50Hz 1Sec	8/20µs	Note 1	1MHz
	10times	100A		
4532-1200DLF	3	300	1	0.5

Note 1: Insulation resistance test condition:

DC Breakdown Voltage	≤150V	151~400V	401~1000V	1001~2000V	≥2001V
DC Measuring Voltage	50V	100V	250V	500V	1000V

Note 2: At delivery AQL 0.65 Level II,IN ISO 2859.

5 Glossary (IEC 61643-311;GB/T18802.311)

5.1 Gas Discharge Tube

A gap, or several gaps, in an enclosed discharge medium, other than air at atmospheric pressure, designed to protect apparatus or personnel, or both, from high transient voltages.

5.2 DC Breakdown (Spark-over) Voltage(Vs)

The GDT shall be placed for at least 15min when no voltage is applied, the test shall be conducted at a voltage rise rate of 100v/s~2000v/s under this circumstances.

5.3 Maximum Impulse Breakdown Voltage (Vsi)

The maximum voltage rise rate of the measured terminal measured by GDT is $100V/\mu s$, $1000V/\mu s$, or $5000V/\mu s$.

Issued-date: 2024-06-24	Name	Specification Sheet –4532	32			
Revision	A		Page	5		
STANDARD MANUAL						



5.4 Maximum Impulse Discharge Current

GDT can withstand 1 time, More than once or positive and negative each N times of the maximum impact current value (current waveform $8/20\mu S$ or $10/350\mu S$), More than once or N times of impact each interval of 3 minutes.

5.5 Impulse Withstanding Voltage Capacity

At the rated maximum discharge current (open circuit voltage waveform 10x700µs), the GDT shall be able to withstand plus or minus 5 times each at an interval of 3 minutes

5.6 Nominal Discharge Current

Apply rated RMS of ac current of 50Hz*1 second multiply 10 times (each interval is 3 minutes) or Single 9cycles to the product.

5.6 Follow On Current

An alternating current is applied to the standard test circuit (power frequency current is limited by resistance), and a shock current is applied to the GDT product so that it is on, while the current flowing through the GDT product is provided by the connected AC power supply.

5.7 Breakdown time

A voltage source with a fixed voltage gradient (1000V/uS or 5000V/uS) is applied to both ends of the GDT to measure the response time (there is a delay time between the moment when the transient overvoltage starts acting on both ends of the discharge tube and the actual discharge time of the product)

5.8 Maximum continuous operating voltage

Maximum continuous AC/DC voltage that can be applied when the product is in normal operation.

5.9 Impulse Life

The GDT can withstand rated times of current shock (current waveform: $8/20\mu s$, $10/1000\mu s$ or $5/320\mu s$), The interval of each shock is 3 minutes.

5.10 DC Holdover Voltage

Under the specified circuit conditions, GDT after a shock discharge, it from the conduction and restore to the high impedance state of the applied DC voltage (DC test voltage is divided into 52V/80V and 135V three grades).

5.11 Minimum Insulation Resistance

A rated voltage is applied between the two endpoints of the GDT to measure the resistance.

5.12 Maximum Capacitance

Measure the capacitance between the two ends of the GDT using a test frequency of 1MHz and a test voltage of 0.5V.

5.13 Arc Voltage

The voltage measured across the tube while in lowest impedance state or arc mode.

Ī	Issued-date: 2024-06-24	Name	Specification Sheet –4532				
	Revision	A		Page	6		
	STANDARD MANUAL						



5.14 Glow Voltage

The peak value of the voltage drop across the GDT when a glow-current is flowing.

5.15 AC/DC withstand Voltage

By applying a certain voltage (AC/DC) to the product through high voltage equipment test, to ensure that the product is not broken down.

6 Technical Term or Test methods

6.1 Storage onditions (-40°C~105°C)

Storage conditions without voltage applied

Please store products in the environments of dry, ventilation and no-corrosion, period One year.

6.2 Operational temperature (-40°C~105°C)

Gas discharge tubes shall be capable of withstanding during operational conditions without damage

6.3 Test methods:

Unless otherwise specified, all tests are made under environmental conditions as given below, Temperature:15~35°C,Relative humidity:25~80%RH.

7 Warning

- 7.1 Do not operate gas discharge tube in power supply networks, whose maximum operation voltage exceeds the minimum spark-overvoltage of the gas discharge tube.
- 7.2 Gas discharge tube may become hot in the event of longer periods of current stress (burn risk). In the event of overload the connectors may fail or the component may be destroyed.
- **7.3** If the contacts of the surge arresters are defective, current load can cause sparks and loud noises.
- 7.4 Gas discharge tube must be handled with care and must not be dropped
- 7.5 Do not continue to use damaged gas discharge tube.

8 Validity

- **8.1** If the content of these specifications is inadequate or need revising, it will be revised after both parties' agreement.
- **8.2** The specifications can be used temporarily during the period of approval. If you have no any objection or not return one hardcopy to us within one month, these specifications will be operated as a valid document. If any change, we will inform you.

Issued-date: 2024-06-24	Name	Specification Sheet –4532				
Revision	A		Page	7		
STANDARD MANUAL						